SCHUYLER COUNTY
WATERSHED PROTECTION AGENCY

James D. Howell
Director
Phone (607) 535-2208

208 W. Broadway St., Room 305
Montour Falls, NY 14865

CERTIFICATE OF COMPLIANCE
RESULTS OF INVESTIGATION OF INDIVIDUAL SEWAGE AND/OR WATER SYSTEM

Owner	Claude N. & Patricia B. States Phone: 594-3345
Address	118 State Route 228, Odessa, NY 14869
Location (Town)	118 State Route 228, Village of Odessa, Town of Catharine
Interviewee	Owner
Former Owner	Since 1972; Earl McDougal
Requested By	Owner
Buyer	Sandra Litwhiler, Trumansburg

SEWAGE DISPOSAL SYSTEM

Constructed in compliance with standards: On File
Constructed By: States Farms & Fran Smith Date: 1980 & 2003
Septic Tank Type & Size: 1000 gallon aerobic unit Date Last Pumped: 2003 – Smith & Peterson
Type of Treatment System: Four 40 ft absorption trenches

X 1) System appeared, upon visual examination, to be operating satisfactorily at the time of inspection. **
2) Insufficient evidence available to make a determination.
___ 3) System is unsatisfactory.

REMARKS: With the exception of the kitchen sink and clothes washer, all other household wastewater drains directly into the aerobic tank. The 1000 gallon tank and absorption system was installed by States Farms in 1980. Fran Smith installed the aerobic bacteria inoculator July 2003 with the approval of this Agency. A maintenance contract must be in place for the life of the aerobic unit.

WATER SUPPLY SYSTEM

Type: Community Depth: Cased to
Date Water Sampled: Routinely by Municipality Analysis Attached:
Water Quality Was: Satisfactory X Unsatisfactory __Lab Identification #

REMARK: The home is provided water from the Village of Odessa Community Municipal water system which is approved by the New York State Health Department.

DATE: July 3, 2003 BY: James D. Howell

NOTE: Normally septic tanks should be pumped every two to four years.

*INFORMATION SUPPLIED BY OTHERS, THEREFORE UNABLE TO VERIFY INFORMATION.

**THE SATISFACTORY NOTATION ABOVE IS NOT INTENDED IN ANY WAY TO DESCRIBE OR IMPLY THE CONDITION, INTEGRITY, CONSTRUCTION OF/OR CONTINUED SATISFACTORY USE OF ANY COMPONENT(S) OF THE AFOREMENTIONED WASTEWATER TREATMENT SYSTEM(S) BOTH DURING AND BEYOND THE DATE OF THE

Invoice

Watershed Protection Agency

Rural Urban Center, Room 305
208 W. Broadway, Montour Falls, NY 14865
Phone: 607-535-2208

Date	Invoice #
7/2/2003	3-377

Bill To

States, Claude N. & Patricia B
118 State Route 228
Odessa, NY 14869

P.O. Number	Terms	Project

Quantity	Description	Rate	Amount
	Wastewater system evaluation for property transfer	80.00	80.00
	Permit to install Aerobic unit	45.00	45.00
		Total	$125.00